

TICKET #IE314_193

The manual power isolation switch(s) at the FSTD are not identified as such.

I have added an identification placard next to the Power isolation switches. Please see image below.



Closing Ticket.